

Отчет о потреблении тепловой энергии и теплоносителя за Июль 2016 г.

Потребитель: Жилой дом
Адрес: ул. Чапаева 28

Тип прибора:
Номер прибора:
Теплосистема:

ТСРВ-022
402262✓
2

Температура холодной воды, °C: 0

Дата	п, ч	Подающий трубопровод				Обратный трубопровод				dt °C	dG, т	W3, Гкал
		W1, Гкал	t1, °C	m1, т	P1, МПа	W2, Гкал	t2, °C	m2, т	P2, МПа			
24.06.16	24.00	3.466	63.29	54.740	0.60	2.108	50.46	41.740	0.50	12.83	13.000	1.359
25.06.16	24.00	3.406	63.75	53.380	0.60	2.060	50.55	40.720	0.50	13.20	12.660	1.346
26.06.16	24.00	3.442	63.17	54.450	0.60	2.050	50.28	40.730	0.50	12.89	13.720	1.393
27.06.16	24.00	3.394	64.37	52.670	0.60	2.071	50.78	40.760	0.50	13.59	11.910	1.321
28.06.16	24.00	3.439	63.23	54.340	0.60	2.097	50.28	41.650	0.50	12.95	12.690	1.342
29.06.16	24.00	3.511	63.32	55.440	0.60	2.183	50.60	43.110	0.50	12.72	12.330	1.330
30.06.16	24.00	3.423	63.63	53.740	0.60	2.162	50.66	42.640	0.50	12.97	11.100	1.260
01.07.16	24.00	3.442	63.92	53.800	0.60	2.174	50.97	42.610	0.50	12.95	11.190	1.268
02.07.16	24.00	3.537	64.37	54.890	0.60	2.216	51.52	42.980	0.50	12.85	11.910	1.320
03.07.16	24.00	3.466	63.11	54.870	0.60	2.205	50.98	43.220	0.50	12.13	11.650	1.261
04.07.16	23.97	3.408	63.36	53.760	0.60	2.195	51.08	42.930	0.50	12.28	10.830	1.214
05.07.16	24.00	3.442	63.78	53.920	0.60	2.183	50.89	42.870	0.50	12.89	11.050	1.258
06.07.16	24.00	3.377	63.29	53.330	0.60	2.154	50.28	42.790	0.50	13.01	10.540	1.225
07.07.16	24.00	3.408	63.59	53.570	0.60	2.177	50.48	43.090	0.50	13.11	10.480	1.232
08.07.16	24.00	3.270	63.61	51.360	0.60	2.048	49.98	40.930	0.50	13.63	10.430	1.222
09.07.16	24.00	3.301	64.45	51.180	0.60	2.010	50.35	39.890	0.50	14.10	11.290	1.291
10.07.16	24.00	3.341	64.17	52.030	0.60	2.004	50.17	39.900	0.50	14.00	12.130	1.337
11.07.16	24.00	3.236	63.43	50.990	0.60	1.984	49.78	39.820	0.50	13.65	11.170	1.253
12.07.16	24.00	3.205	63.18	50.670	0.60	1.989	49.79	39.900	0.50	13.39	10.770	1.215
13.07.16	24.00	3.263	64.03	50.910	0.60	2.006	50.24	39.910	0.50	13.79	11.000	1.255
14.07.16	22.60	3.019	63.41	47.600	0.60	1.869	49.89	37.420	0.50	13.52	10.180	1.152
15.07.16	23.96	3.241	63.60	50.930	0.60	1.975	49.96	39.490	0.50	13.64	11.440	1.266
16.07.16	23.80	3.196	64.13	49.780	0.60	1.979	50.18	39.390	0.50	13.95	10.390	1.217
17.07.16	23.91	3.339	63.46	52.560	0.60	1.959	49.79	39.320	0.50	13.67	13.240	1.378
18.07.16	24.00	3.308	63.53	52.040	0.60	1.963	49.94	39.260	0.50	13.59	12.780	1.346
19.07.16	24.00	3.270	63.70	51.290	0.60	1.952	49.98	39.020	0.50	13.72	12.270	1.318
20.07.16	24.00	3.258	63.78	51.030	0.60	1.973	50.05	39.380	0.50	13.73	11.650	1.285
21.07.16	24.00	3.258	63.94	50.940	0.60	1.981	50.11	39.490	0.50	13.83	11.450	1.279
22.07.16	24.00	3.313	64.39	51.400	0.60	1.982	50.46	39.250	0.50	13.93	12.150	1.331
23.07.16	24.00	3.294	63.79	51.590	0.60	1.965	50.26	39.070	0.50	13.53	12.520	1.328
Среднее:		3.343	63.69	52.450		2.056	50.36	40.783		13.33	11.667	1.287
Итого:	718.24	100.272		1573.200		61.674		1223.280			349.920	38.599

Показания счетчиков:

Дата и время	m1, т	m2, т	W1, Гкал	W2, Гкал	W3, Гкал
23.06.2016 23:00	46960.560	43694.230	3181.302	2237.793	943.744
23.07.2016 23:00	48533.760	44917.510	3281.574	2299.466	982.344

Общее время работы = Траб + Тотк Тнс1 Тнс2 Тнс3
720.02 718.24 + 1.78 0.00 0.00 0.00

Ответственный за учет тепловой энергии: _____ / _____
Отчет принят _____ 200 г. _____ / _____

ООО «СК С»
ПРЕДСТАВИТЕЛЬСТВО
УВАРОВ С.В.