

Отчет о потреблении тепловой энергии и теплоносителя за Апрель 2016 г.

Потребитель: Жилой дом
Адрес: ул. Чапаева 28

Тип прибора: ТСРВ-022
Номер прибора: 402262
Теплосистема: 2

Температура холодной воды, °C: 0

Дата	n, ч	Подающий трубопровод				Обратный трубопровод				dt °C	dG, т	W3, Гкал
		W1, Гкал	t1, °C	m1, т	P1, МПа	W2, Гкал	t2, °C	m2, т	P2, МПа			
26.03.16	24.00	16.791	64.56	259.890	0.60	12.301	50.15	245.020	0.50	14.41	14.870	4.491
27.03.16	24.00	16.901	64.57	261.570	0.60	12.349	50.30	245.300	0.50	14.27	16.270	4.552
28.03.16	24.00	12.425	64.32	193.010	0.60	8.755	48.90	178.860	0.50	15.42	14.150	3.668
29.03.16	24.00	11.744	65.21	179.970	0.60	7.870	47.30	166.200	0.50	17.91	13.770	3.873
30.03.16	24.00	15.277	64.76	235.740	0.60	10.884	49.06	221.630	0.50	15.70	14.110	4.394
31.03.16	24.00	14.835	64.43	230.060	0.60	10.505	48.35	217.040	0.50	16.08	13.020	4.329
01.04.16	24.00	15.176	64.92	233.600	0.60	10.719	48.70	219.890	0.50	16.22	13.710	4.457
02.04.16	24.00	15.224	64.61	235.460	0.60	10.675	48.43	220.210	0.50	16.18	15.250	4.550
03.04.16	24.00	15.222	64.74	234.950	0.60	10.619	48.53	218.600	0.50	16.21	16.350	4.602
04.04.16	24.00	15.131	64.68	233.750	0.60	10.634	48.50	219.020	0.50	16.18	14.730	4.496
05.04.16	24.00	15.248	64.69	235.530	0.60	10.705	48.50	220.490	0.50	16.19	15.040	4.543
06.04.16	24.00	15.155	64.74	233.940	0.60	10.680	48.57	219.660	0.50	16.17	14.280	4.476
07.04.16	24.00	15.212	64.75	234.780	0.60	10.859	48.94	221.660	0.50	15.81	13.120	4.353
08.04.16	24.00	15.265	64.60	236.120	0.60	10.927	48.90	223.250	0.50	15.70	12.870	4.337
09.04.16	24.00	15.432	64.79	238.020	0.60	10.927	49.02	222.670	0.50	15.77	15.350	4.505
10.04.16	24.00	15.379	64.60	237.880	0.60	10.870	48.81	222.450	0.50	15.79	15.430	4.508
11.04.16	24.00	15.312	64.55	237.040	0.60	10.888	48.75	223.120	0.50	15.80	13.920	4.424
12.04.16	24.00	15.329	64.81	236.370	0.60	10.981	49.01	223.820	0.50	15.80	12.550	4.350
13.04.16	24.00	15.343	64.45	237.860	0.60	10.970	48.89	224.150	0.50	15.56	13.710	4.373
14.04.16	23.96	15.281	64.53	236.600	0.60	10.882	48.71	223.160	0.50	15.82	13.440	4.398
15.04.16	24.00	15.200	64.64	235.010	0.60	10.775	48.61	221.450	0.50	16.03	13.560	4.427
16.04.16	24.00	15.668	64.88	241.290	0.60	10.721	48.89	219.080	0.50	15.99	22.210	4.946
17.04.16	24.00	15.606	64.92	240.230	0.60	10.812	49.15	219.760	0.50	15.77	20.470	4.796
18.04.16	24.00	15.324	64.34	237.990	0.60	10.922	49.10	222.210	0.50	15.24	15.780	4.401
19.04.16	24.00	15.332	64.67	236.890	0.60	11.006	49.15	223.720	0.50	15.52	13.170	4.325
20.04.16	24.00	15.403	64.81	237.500	0.60	11.001	49.14	223.630	0.50	15.67	13.870	4.404
21.04.16	24.00	15.406	64.67	237.990	0.60	10.980	48.96	224.020	0.50	15.71	13.970	4.424
22.04.16	24.00	15.429	64.81	237.890	0.60	11.042	49.19	224.280	0.50	15.62	13.610	4.387
23.04.16	24.00	15.377	64.57	238.000	0.60	10.922	48.80	223.610	0.50	15.77	14.390	4.455
24.04.16	24.00	15.480	64.73	238.950	0.60	10.916	48.89	223.060	0.50	15.84	15.890	4.563
25.04.16	24.00	15.274	64.52	236.570	0.60	10.894	48.78	223.120	0.50	15.74	13.450	4.381
Среднее:		15.199	64.67	234.853		10.774	48.87	220.133		15.80	14.720	4.425
Итого:	743.96	471.181		7280.450		333.992		6824.140			456.310 ✓	137.189 ✓

Показания счетчиков:

Дата и время	m1,т	m2,т	W1,Гкал	W2,Гкал	W3,Гкал
25.03.2016 23:00	34685.070	32799.910	2390.455	1696.238	694.453
25.04.2016 23:00	41965.520	39624.050	2861.635	2030.230	831.642

Общее время работы = Траб + Тотк Тнс1 Тнс2 Тнс3
744.00 743.96 + 0.04 0.00 0.00 0.00

Ответственный за учет тепловой энергии: _____ / _____ /
Отчет принят _____ 200 г. _____ / _____ /

С.В. УВАРОВ
С.В. УВАРОВ