

Отчет о потреблении тепловой энергии и теплоносителя за Июнь 2016 г.

Потребитель: Жилой дом
Адрес: ул. Чапаева 28

Тип прибора: ТСРВ-022
Номер прибора: 402262
Теплосистема: 2

Температура холодной воды, °C: 0

Дата	п, ч	Подающий трубопровод				Обратный трубопровод				dt °C	dG, т	W3, Гкал
		W1, Гкал	t1, °C	m1, т	P1, МПа	W2, Гкал	t2, °C	m2, т	P2, МПа			
26.05.16	24.00	4.495	63.82	70.360	0.60	3.155	53.40	59.030	0.50	10.42	11.330	1.339
27.05.16	24.00	4.423	63.26	69.890	0.60	3.095	52.75	58.630	0.50	10.51	11.260	1.329
28.05.16	24.00	4.600	64.02	71.830	0.60	3.192	53.40	59.730	0.50	10.62	12.100	1.409
29.05.16	24.00	4.617	63.99	72.080	0.60	3.215	53.50	60.050	0.50	10.49	12.030	1.401
30.05.16	24.00	4.648	64.05	72.500	0.60	3.291	53.76	61.160	0.50	10.29	11.340	1.356
31.05.16	24.00	4.598	63.87	71.950	0.60	3.258	53.56	60.790	0.50	10.31	11.160	1.341
01.06.16	24.00	4.452	63.61	69.940	0.60	3.147	53.18	59.110	0.50	10.43	10.830	1.306
02.06.16	24.00	4.717	64.06	73.580	0.60	2.502	53.07	47.110	0.50	10.99	26.470	2.216
03.06.16	24.00	3.747	63.86	58.630	0.60	2.447	53.29	45.890	0.50	10.57	12.740	1.300
04.06.16	24.00	4.514	64.15	70.320	0.60	2.623	52.98	49.480	0.50	11.17	20.840	1.891
05.06.16	24.00	4.297	63.84	67.230	0.60	2.600	52.50	49.490	0.50	11.34	17.740	1.695
06.06.16	24.00	3.857	63.81	60.410	0.60	2.544	51.91	48.970	0.50	11.90	11.440	1.314
07.06.16	24.00	3.587	64.08	55.960	0.60	2.191	50.82	43.090	0.50	13.26	12.870	1.397
08.06.16	24.00	3.793	64.15	59.060	0.60	2.057	51.20	40.140	0.50	12.95	18.920	1.734
09.06.16	24.00	3.800	63.82	59.530	0.60	1.882	50.92	36.910	0.50	12.90	22.620	1.921
10.06.16	24.00	3.757	63.48	59.100	0.60	1.834	50.40	36.360	0.50	13.08	22.740	1.921
11.06.16	24.00	3.673	63.80	57.540	0.60	1.840	50.47	36.430	0.50	13.33	21.110	1.834
12.06.16	24.00	3.712	63.65	58.270	0.60	1.831	50.31	36.370	0.50	13.34	21.900	1.880
13.06.16	24.00	3.716	63.59	58.420	0.60	1.843	50.22	36.650	0.50	13.37	21.770	1.875
14.06.16	24.00	3.521	64.21	54.760	0.60	1.808	50.50	35.760	0.50	13.71	19.000	1.711
15.06.16	24.00	2.637	61.94	42.540	0.60	1.213	47.45	25.550	0.50	14.49	16.990	1.424
16.06.16	24.00	2.420	62.85	38.460	0.60	0.974	45.64	21.300	0.50	17.21	17.160	1.446
17.06.16	24.00	2.400	63.21	37.980	0.60	1.211	46.26	26.150	0.50	16.95	11.830	1.191
18.06.16	24.00	2.410	63.07	38.170	0.60	1.204	45.93	26.200	0.50	17.14	11.970	1.204
19.06.16	24.00	2.548	63.34	40.210	0.60	1.219	45.79	26.590	0.50	17.55	13.620	1.330
20.06.16	24.00	3.074	63.03	48.730	0.60	1.843	48.95	37.600	0.50	14.08	11.130	1.231
21.06.16	24.00	3.571	64.41	55.390	0.60	2.240	51.17	43.740	0.50	13.24	11.650	1.330
22.06.16	24.00	3.590	63.93	56.100	0.60	2.330	51.28	45.400	0.50	12.65	10.700	1.259
23.06.16	24.00	3.611	63.88	56.480	0.60	2.333	51.33	45.400	0.50	12.55	11.080	1.278
Среднее:		3.751	63.68	58.808		2.239	50.89	43.417		12.79	15.391	1.513
Итого:	696.00	108.787		1705.420		64.923		1259.080			446.340	43.863

Показания счетчиков:

Дата и время	m1,т	m2,т	W1,Гкал	W2,Гкал	W3,Гкал
25.05.2016 23:00	45255.140	42435.150	3072.515	2172.870	899.881
23.06.2016 23:00	46960.560	43694.230	3181.302	2237.793	943.744

Общее время работы = Траб + Тотк Тнс1 Тнс2 Тнс3
696.01 696.00 + 0.01 0.00 0.00 0.00

Ответственный за учет тепловой энергии: _____ / _____ /

Отчет принят _____ 200 г. _____ / _____ /

000 «СН
ПРОИЗВ.
УВАРОВ С.В.